



## Malvern Fire Company

424 East King Street  
P.O. Box 435  
Malvern, PA 19355

Main 610-647-0693  
Fax 610-647-0249  
[www.malvernfireco.com](http://www.malvernfireco.com)

---

To: Tiffany Loomis  
Borough Manager & Zoning Officer

4/8/2022

From: Jim Rapp, Chief 

Reference: Plan Review for property located at 551 Sugartown Road

---

The only concern I have is the elevation change from both Monument Ave. and Sugartown Road, if the builder stays true to the drawing the approach angle should be no problem.

The approach angle for both the Engine and Ladder are approx. 8 degrees over eight feet to front wheels.